


PR



6 3 3 7

2-wire HART® Transmitter

No. 6337V101-UK
From ser. no. 110944345



ATEX Ex

SIGNALS THE BEST

DK ▶ PR electronics A/S tilbyder et bredt program af analoge og digitale signalbehandlingsmoduler til industriel automation. Programmet består af Isolatorer, Displays, Ex-barrierer, Temperaturtransmittere, Universaltransmittere mfl. Vi har modulerne, du kan stole på i selv barske miljøer med elektrisk støj, vibrationer og temperaturudsving, og alle produkter opfylder de strengeste internationale standarder. Vores motto »Signals the Best« er indbegrebet af denne filosofi – og din garanti for kvalitet.

UK ▶ PR electronics A/S offers a wide range of analogue and digital signal conditioning devices for industrial automation. The product range includes Isolators, Displays, Ex Interfaces, Temperature Transmitters, and Universal Devices. You can trust our products in the most extreme environments with electrical noise, vibrations and temperature fluctuations, and all products comply with the most exacting international standards. »Signals the Best« is the epitome of our philosophy – and your guarantee for quality.

FR ▶ PR electronics A/S offre une large gamme de produits pour le traitement des signaux analogiques et numériques dans tous les domaines industriels. La gamme de produits s'étend des transmetteurs de température aux afficheurs, des isolateurs aux interfaces SI, jusqu'aux modules universels. Vous pouvez compter sur nos produits même dans les conditions d'utilisation sévères, p.ex. bruit électrique, vibrations et fluctuations de température. Tous nos produits sont conformes aux normes internationales les plus strictes. Notre devise »SIGNALS the BEST« c'est notre ligne de conduite - et pour vous l'assurance de la meilleure qualité.

DE ▶ PR electronics A/S verfügt über ein breites Produktprogramm an analogen und digitalen Signalverarbeitungsgeräte für die industrielle Automatisierung. Dieses Programm umfasst Displays, Temperaturtransmitter, Ex- und galvanische Signaltrenner, und Universalgeräte. Sie können unsere Geräte auch unter extremen Einsatzbedingungen wie elektrisches Rauschen, Erschütterungen und Temperaturschwingungen vertrauen, und alle Produkte von PR electronics werden in Übereinstimmung mit den strengsten internationalen Normen produziert. »Signals the Best« ist Ihre Garantie für Qualität!

2-WIRE HART® TRANSMITTER

PRETRANS 6337

CONTENTS

EC declaration of conformity	2
Application	3
Technical characteristics	3
Mounting / installation / programming	4
Applications.....	5
Accessories	6
Ordering codes for 6337	6
Technical data	6
Switching HART® protocol revision	9
Connections	11
Block diagram	13
Programming.....	14
Connection of transmitters in multidrop mode	16
Appendix	17
ATEX Installation Drawing - 6337A.....	18
IECEx Installation Drawing - 6337A	20
ATEX Installation Drawing - 6337D	22
IECEx Installation Drawing - 6337D	24
FM Installation Drawing - 6337D.....	26
CSA Installation Drawing - 6337D.....	27

EC DECLARATION OF CONFORMITY

As manufacturer

PR electronics A/S
Lerbakken 10
DK-8410 Rønde

hereby declares that the following product:

Type: 6337
Name: 2-wire HART® transmitter

is in conformity with the following directives and standards:

The EMC Directive 2004/108/EC and later amendments

EN 61326-1 : 2006

For specification of the acceptable EMC performance level, refer to the electrical specifications for the device.

The ATEX Directive 94/9/EC and later amendments

EN 60079-0 : 2009, EN 60079-11 : 2007,

EN 60079-15 : 2010, EN 60079-26 : 2007

and EN 61241-11 : 2006

ATEX certificate: KEMA 10ATEX0006 X (6337A)

ATEX certificate: KEMA 09ATEX0148 (6337D)

Notified body

DEKRA Certification B.V. (0344)
Utrechtseweg 310, 6812 AR Arnhem
P.O. Box 5185, 6802 ED Arnhem
The Netherlands



Kim Rasmussen
Manufacturer's signature

Rønde, 23 March 2012

PRETRANS 6337

2-WIRE HART® TRANSMITTER

- *RTD, TC, Ohm, or mV input*
- *2 analogue inputs and 5 device variables with status available*
- *HART® protocol revision selectable from HART® 5 or HART® 7*
- *Hardware assessed for use in SIL applications*
- *Mounting on a DIN rail in safe area or hazardous gas and dust area*

Application

- Linearised temperature measurement with TC and RTD sensors e.g Pt100 and Ni100.
- HART® communication and 4...20 mA analogue PV output for individual, difference or average temperature measurement of up to two RTD or TC input sensors.
- Conversion of linear resistance to a standard analogue current signal, e.g from valves or Ohmic level sensors.
- Amplification of bipolar mV signals to standard 4...20 mA current signals.
- Up to 63 transmitters (HART® 7) can be connected in a multidrop communication setup.

Technical characteristics

- HART® protocol revision can be changed by user configuration to either HART® 5 or HART® 7 protocol.
- The HART® 7 protocol offers:
 - Long Tag numbers of up to 32 characters.
 - Enhanced Burst Mode and Event notification with time stamping.
 - Device variable and status mapping to any dynamic variable PV, SV, TV or QV.
 - Process signal trend measurement with logs and summary data.
 - Automatic event notification with time stamps.
 - Command aggregation for higher communication efficiency.
- 6337 is designed according to strict safety requirements and is therefore suitable for applications in SIL installations.
- Continuous check of vital stored data.
- Meeting the NAMUR NE 21 recommendations, the 6337 HART transmitter ensures top measurement performance in harsh EMC environments.
Additionally, the 6337 meets NAMUR NE43 and NE89 recommendations.


Mounting / installation / programming

- DIN rail mounting with up to 84 channels per metre.
- Configuration via standard HART® communication interfaces or by PR 5909 Loop Link.
- NB: As Ex barrier for 6337D we recommend 5106B and 9106B.




APPLICATIONS

RTD to 4...20 mA




2-wire installation
in control room

TC to 4...20 mA




2-wire installation
in control room

Resistance
to 4...20 mA




2-wire installation
in control room

mV to 4...20 mA



2-wire installation
in control room

Difference or average
RTD, TC or mV



2-wire installation
in control room

Ordering codes for 6337

Type	Version	Galvanic isolation	Channels
6337	Standard ATEX, CSA, FM & IECEx	: A : D	1500 VAC : 2 Single Double : A : B

Accessories

5909 = Loop Link USB interface and PReset Software

5910 / 5910Ex = CJC connector for channel 1

5913 / 5913Ex = CJC connector for channel 2

Technical data

Environmental conditions:

Specifications range.....	-40°C to +60°C
Storage temperature	-40°C to +85°C
Calibration temperature.....	20...28°C
Relative humidity	< 95% RH (non-cond.)
Protection degree.....	IP20

Mechanical specifications:

Dimensions (HxWxD).....	109 x 23.5 x 104 mm
Weight approx., 1- / 2-ch. version	150 / 200 g
DIN rail type.....	DIN EN 60715 - 35mm
Wire size.....	0.13...2.08 mm ² / AWG 26...14 stranded wire
Screw terminal torque.....	0.5 Nm

Common electrical specifications:

Supply voltage, DC:

Standard.....	8.0...35 V
ATEX, CSA, FM & IECEx	8.0...30 V

Voltage drop..... 8.0 V

Isolation voltage, test / operation..... 1.5 kVAC / 50 VAC

Isolation voltage, channel 1 / channel 2:

Standard.....	3.75 kVAC
ATEX, CSA, FM & IECEx	1.5 kVAC

Signal / noise ratio > 60 dB
 Communications interface Loop Link & HART[®]
 Response time (programmable)..... 1...60 s
 Accuracy, the greater of general and basic values:

General values		
Input type	Absolute accuracy	Temperature coefficient
All	≤ ±0.05% of span	≤ ±0.005% of span / °C

Basic values		
Input type	Basic accuracy	Temperature coefficient
Pt50 - Pt1000	≤ ±0.1°C	≤ ±0.005°C/°C
Ni50 - Ni1000	≤ ±0.2°C	≤ ±0.005°C/°C
Lin. R	≤ ±0.1 Ω	≤ ±5 mW / °C
Volt	≤ ±10 µV	≤ ±0.5 µV / °C
TC type: E, J, K, L, N, T, U	≤ ±0.5°C	≤ ±0.025°C / °C
TC type: B ¹ , Lr, R, S, W3,W5	≤ ±1°C	≤ ±0.1°C / °C
TC type:B ²	≤ ±3°C	≤ ±0.3°C / °C
TC type:B ³	≤ ±8°C	≤ ±0.8°C / °C
TC type:B ⁴	not specified	not specified

TC B¹ accuracy specification range..... > 400°C
 TC B² accuracy specification range..... > 160°C < 400°C
 TC B³ accuracy specification range > 85°C < 160°C
 TC B⁴ accuracy specification range < 85°C

TC cold junction compensation < ±1.0°C
 Max. offset on input signal..... 50% of selec. max. value

EMC immunity influence	< ±0.1% of span
Extended EMC immunity:	
NAMUR NE 21, A criterion, burst	< ±1% of span

Input specifications:**RTD input types:**

RTD type	Min. value	Max. values	Min. span	Standard
Pt100	-200°C	+850°C	10°C	IEC 60751
Ni100	-60°C	+250°C	10°C	DIN 43760
Lin. R	0 Ω	7000 Ω	25 Ω	-----

Pt50, Pt100, Pt200, Pt500, Pt1000, Ni50, Ni100, Ni120, Ni1000

Cable resistance per wire (max.) 5 Ω

(up to 50 Ω per wire is possible with reduced measurement accuracy)

Sensor current Nom. 0.2 mA

TC input types:

Type	Min. temperature	Max. temperature	Min. span	Standard
B	0°C	+1820°C	100°C	IEC584
E	-100°C	+1000°C	50°C	IEC584
J	-100°C	+1200°C	50°C	IEC584
K	-180°C	+1372°C	50°C	IEC584
L	-200°C	+900°C	50°C	DIN 43710
Lr	-200°C	+800°C	50°C	GOST 3044-84
N	-180°C	+1300°C	50°C	IEC584
R	-50°C	+1760°C	100°C	IEC584
S	-50°C	+1760°C	100°C	IEC584
T	-200°C	+400°C	50°C	IEC584
U	-200°C	+600°C	50°C	DIN 43710
W3	0°C	+2300°C	100°C	ASTM E988-90
W5	0°C	+2300°C	100°C	ASTM E988-90

Cold junction compensation (CJC):

Constant, internal or external via a Pt100 or Ni100 sensor

mV input:

Voltage input range -800...+800 mV

Min. span 2.5 mV

Input resistance 10 MΩ

Output specifications and HART®:

Signal range	4...20 mA
Min. signal range.....	16 mA
Updating time.....	440 ms
Load resistance.....	$\leq (V_{\text{supply}} - 8) / 0.023 [\Omega]$
Sensor error detection, programmable.....	3.5...23mA
NAMUR NE43 Upscale	23 mA
NAMUR NE43 Downscale.....	3.5 mA
HART® protocol revisions	HART® 5 and HART® 7

Switching HART® protocol revision

It is possible to change the HART® protocol revision by using the PReset software and a PR 5909 Loop Link interface or a HART® compatible modem. Other HART® configuration tools like a handheld terminal can also be used.

Switching protocol from HART® 7 to HART® 5:

Procedure when using the PR PReset Software:

Enter the 6337 PReset tab "**HART**" and open the folder "**Methods**".

Click "**Device Password / Write Protection / Protocol...**" and select "**Change protocol to HART 5**" in the pop-up window - acknowledge by pressing OK.

Please note that this action will change the 6337 into a 6335 device.

Switching from HART®-5 to HART®-7:

Please note that this is only possible if the transmitter is label marked as "6337"!

Enter the 6335 PReset tab "**OPTIONS**" and click "**Protect**".

Write protection must be set ON and select **Change Password**.

Type in the **New Password "HARTREV7"** and **Re-enter "HARTREV7"**. Press OK.

Switch **Write protection OFF** and write enable the device by typing in the

Password "-CHANGE-" in the top menu - acknowledge by pressing OK.

The above action will reset the password to the default active password ("*****") and restart the device in the updated HART 7 mode with write protection disabled.

Please note that the configuration changed flags and configuration changed counter are **not** updated by this command.

Approvals:

EMC 2004/108/EC EN 61326-1
GOST R

Ex / I.S.:

6337A:

ATEX 94/9/EC..... KEMA 10ATEX0006 X
IECEx KEM 10.0084 X

6337D:

ATEX 94/9/EC..... KEMA 09ATEX0148
IECEx KEM 10.0083 X
FM certificate 2D5A7
CSA certificate 1125003
GOST Ex


Functional Safety:

Hardware assessed for use in SIL applications

FMEDA report - www.prelectronics.com



CONNECTIONS

Inputs:




CONNECTIONS

Inputs:



BLOCK DIAGRAM



PROGRAMMING

PRetrans 6337 can be configured in the following 3 ways:


1. With PR electronics A/S' communications interface Loop Link and PReset PC configuration software.
2. With a HART® modem and PReset PC configuration software.
3. With a HART® communicator with PR electronics A/S' DDL driver.

1: Loop Link

For programming please refer to the drawing below and the help functions in PReset.


When communicating with non-installed devices, connectors 11, 12, 13, 14 (channel 1) and 21, 22, 23, 24 (channel 2) can be dismantled in the safe area to connect the terminals of the communications interface to the pins.

Loop Link is not approved for communication with devices installed in hazardous (Ex) area.




2: HART® modem

For programming please refer to the drawing below and the help functions in PReset.




3: HART® communicator

For programming please refer to the drawing below. To get access to product-specific commands, the HART® communicator must be loaded with the PR electronics A/S DDL driver. This can be ordered either at the HART® Communication Foundation or PR electronics A/S.



CONNECTION OF TRANSMITTERS IN MULTIDROP MODE

- The HART® communicator or a PC modem can be connected across AB or BC.



- The outputs of max. 63 transmitters can be connected in parallel for a digital HART® communication on 2-wires.
- Before it is connected, each transmitter must be configured with a unique number from 1 to 63. If 2 transmitters are configured with the same number, both will be excluded. The transmitters must be programmed for multidrop mode (with a fixed output signal of 4 mA). Maximum current in the loop is therefore 252 mA.
- The communication is either by means of a HART® communicator or a HART® modem.
- The PReset PC configuration software can configure the individual transmitter for multidrop mode and provide it with a unique polling address.

APPENDIX

ATEX INSTALLATION DRAWING - 6337A

IECEx INSTALLATION DRAWING - 6337A

ATEX INSTALLATION DRAWING - 6337D

IECEx INSTALLATION DRAWING - 6337D

FM INSTALLATION DRAWING NO. 6335QF01

CSA INSTALLATION DRAWING NO. 6335QC02

ATEX Installation drawing

For safe installation of 6335A, 6336A or 6337A the following must be observed. The module shall only be installed by qualified personnel who are familiar with the national and international laws, directives and standards that apply to this area.

Year of manufacture can be taken from the first two digits in the serial number.

ATEX Certificate KEMA 10ATEX 0006X

Marking



II 3 G Ex nA [ic] IIC T6 Gc
II 3 G Ex ic IIC T6 Gc
II 3 D Ex ic IIIC Dc

Standards EN 60079-0 : 2009, EN 60079-11:2007,
EN 60079-15: 2010, EN 61241-11:2006


T6: -40°C to 60 °C

Hazardous Area Zone 2 or Zone 22

Terminal:
41,42,43,44 /
51,52,53,54

Ex nA [ic]


Uo: 9.6 VDC
Io: 28 mA
Po: 67 mW
Lo: 35 mH
Co: 3.5µF



Terminal:
11,12,13,14
21,22,23,24

Ex nA

U ≤ 35 VDC
I = 4 - 20 mA



Ex ic

Ui : 35 VDC
Li : 10 µH
Ci : 2.0 nF

Special conditions for safe use.

Type of protection Ex ic IIC Gc:

The transmitter shall be installed in an enclosure that provides a degree of protection of at least IP54 according to EN60529.

Type of protection Ex ic IIIC Dc:

The transmitter shall be installed in an enclosure providing a degree of protection of at least IP6X according to EN60529. The surface temperature of the enclosure is equal to the ambient temperature +20 K, for a dust layer with a maximum thickness of 5 mm.

IECEx Installation drawing

For safe installation of 6335A, 6336A or 6337A the following must be observed. The module shall only be installed by qualified personnel who are familiar with the national and international laws, directives and standards that apply to this area.

Year of manufacture can be taken from the first two digits in the serial number.

IECEx Certificate IECEx KEM.10.0084X

Marking Ex nA [ic] IIC T6 Gc
Ex ic IIC T6 Gc
Ex ic IIIC Dc

Standards IEC60079-11:2006, IEC60079-0: 2007,
IEC60079-26:2006, IEC60079-15:2010, IEC61241-11:2005


T6: -40°C to 60 °C

Hazardous Area Zone 2 or Zone 22

Terminal:
41,42,43,44 /
51,52,53,54

Ex nA [ic]

Uo: 9.6 VDC
Io: 28 mA
Po: 67 mW
Lo: 35 mH
Co: 3.5µF



Installation notes.

Type of protection Ex ic IIC Gc or Ex nA IIC Gc

The transmitter shall be installed in an enclosure that provides a degree of protection of at least IP54 according to IEC60529.

Type of protection Ex ia IIIC Da:

The transmitter shall be installed in an enclosure that provides a degree of protection of at least IP6X according to IEC60529. The surface temperature of the enclosure is equal to the ambient temperature +20 K, for a dust layer with a maximum thickness of 5 mm.

ATEX Installation drawing



For safe installation of 6335D, 6336D or 6337D the following must be observed. The module shall only be installed by qualified personnel who are familiar with the national and international laws, directives and standards that apply to this area.

Year of manufacture can be taken from the first two digits in the serial number.

ATEX Certificate KEMA 09ATEX 0148

Marking



II 1 G Ex ia IIC T6..T5 Ga
II 1D Ex ia IIIC Da

Standards

EN60079-0:2009, EN60079-11:2007, EN60079-26:2007, EN61241-11:2006

Hazardous area

Zone 0, 1, 2, 20, 21, 22

T5: $-40 \leq Ta \leq 60^{\circ}\text{C}$

T6: $-40 \leq Ta \leq 40^{\circ}\text{C}$

Terminal:

41,42,43,44


Uo: 9.6 VDC

Io: 28 mA

Po: 67 mW

Lo: 35 mH

Co: 3.5 μF



Terminal:

51,52,53,54

Uo: 9.6 VDC

Io: 28 mA

Po: 67 mW

Lo: 35 mH

Co: 3.5 μF

Terminal:

11,12,13,14 and

21,22,23,24

Ui: 30 VDC

Ii: 120 mA

Pi: 0.84 W

Li: 10 μH

Ci: 2.0nF

Installation notes

The sensor circuit is not infallibly galvanic isolated from the supply output circuit. However, the galvanic isolation between the circuits is capable of withstanding a test voltage of 500Vac during 1 minute.

Type of protection Ex ia IIC Ga:

The transmitter shall be installed in an enclosure that provides a degree of protection of at least IP20 according to EN60529.

Type of protection Ex ia IIIC Da:

The transmitter shall be installed in an enclosure that provides a degree of protection of at least IP6X according to EN60529. The surface temperature of the enclosure is equal to the ambient temperature +20 K, for a dust layer with a maximum thickness of 5 mm.

IECEx Installation drawing



For safe installation of 6335D, 6336D or 6337D the following must be observed. The module shall only be installed by qualified personnel who are familiar with the national and international laws, directives and standards that apply to this area.

Year of manufacture can be taken from the first two digits in the serial number.

IECEx Certificate IECEx KEM.10.0084X

Marking Ex ia IIC T6..T5 Ga
Ex ia IIIC Da

Standards: IEC60079-11:2006, IEC60079-0: 2007,
 IEC60079-26:2006, IEC61241-11:2005

Hazardous area

Zone 0, 1, 2, 20, 21, 22

T5: -40 ≤ Ta ≤ 60°C
T6: -40 ≤ Ta ≤ 40°C

Terminal:

41,42,43,44


Uo: 9.6 VDC

Io: 28 mA

Po: 67 mW

Lo: 35 mH

Co: 3.5µF



Terminal:

51,52,53,54


Uo: 9.6 VDC

Io: 28 mA

Po: 67 mW

Lo: 35 mH

Co: 3.5µF



Terminal:

11,12,13,14 and

21,22,23,24

Ui: 30 VDC

Il: 120 mA


Pi: 0.84 W

Li: 10µH

Ci: 2.0nF

Non Hazardous Area

250 < R < 1100 ohm



Ex HART
Communicator



Installation notes

The sensor circuit is not infallibly galvanic isolated from the supply output circuit. However, the galvanic isolation between the circuits is capable of withstanding a test voltage of 500Vac during 1 minute.

For installalation in dust the following instructions apply:

The transmitter shall be mounted in a metal enclosure that is providing a degree of protection of at least IP6X according to IEC 60529.The surface temperature of the enclosure is equal to the ambient temperature +20 K, for a dust layer with a maximum thickness of 5 mm.


Cable entries and blanking elements shall be used that are suitable for the application and correctly installed

FM Installation drawing

Hazardous (Classified) Location
 Class I, Division 1, Group A,B,C,D
 Class I, Zone 0, IIC

T6: $-40 \leq T_a \leq 60^\circ C$

Non Hazardous Location



Installation notes.

For installation in Class I the Transmitter must be installed in a suitable enclosure to meet installation codes stipulated in The National Electrical Code (ANSI-NFPA 70).

Equipment that is FM-approved for intrinsic safety may be connected to barriers based on the Entity Concept. This concept permits interconnection of approved transmitters, meters and other devices in combinations, which have not been specifically examined by FM, provided that the agency's criteria are met. The combination is then intrinsically safe, if the entity concept is acceptable to the authority having jurisdiction over the installation.


The entity concept criteria are as follows: The intrinsically safe devices, other than barriers, must not be a source of power. The maximum voltage $U_I(V_{MAX})$ and current $I_I(I_{MAX})$, and maximum power $P_I(P_{MAX})$, which the device can receive and remain intrinsically safe, must be equal to or greater than the voltage (U_o or V_{OC} or V_t) and current (I_o or I_{SC} or I_t) and the power P_o which can be delivered by the barrier. The sum of the maximum unprotected capacitance (C_o) for each intrinsically safe device and the interconnecting wiring must be less than the capacitance (C_s) which can be safely connected to the barrier. The sum of the maximum unprotected inductance (L_o) for each intrinsically safe device and the interconnecting wiring must be less than the inductance (L_s) which can be safely connected to the barrier. The entity parameters U_o , V_{OC} or V_t and I_o , I_{SC} or I_t , and C_o and L_o for barriers are provided by the barrier manufacturer.

CSA Installation drawing


Hazardous (Classified) Location
Class I, Division 1, Group A,B,C,D
Class I, Zone 0, IIC

T6: -40 ≤ Ta ≤ 60°C

Terminal:
41,42,43,44
Ui: 9.6 VDC
Io: 28 mA
Po: 67 mW
Lo: 35 mH
Co: 3.5µF




Terminal:
51,52,53,54
Ui: 9.6 VDC
Io: 28 mA
Po: 67 mW
Lo: 35 mH
Co: 3.5µF



Non Hazardous Location

250 < R < 1100 ohm



Terminal:
**11,12,13,14 and
21,22,23,24**

Ui: 30 VDC
Ii: 120 mA
Pi: 0.84 W
Li: 10µH
Ci: 2.0nF

Co(Ca) > Σ(Ci+Ccable)
Lo(La) > Σ(Li+Lcable)

Installation notes.

The Transmitter must be installed in a suitable enclosure to meet installation codes stipulated in The Canadian Electrical Code (CEC).

Channel 1 and Channel 2 are separate channels and therefore separate shielded cables shall be used for each channel.

Substitution of components may impair intrinsic safety.



Displays Programmable displays with a wide selection of inputs and outputs for display of temperature, volume and weight, etc. Feature linearisation, scaling, and difference measurement functions for programming via PReset software.



Ex interfaces Interfaces for analogue and digital signals as well as HART® signals between sensors / I/P converters/ frequency signals and control systems in Ex zone 0, 1 & 2 and for some devices in zone 20, 21 & 22.



Isolation Galvanic isolators for analogue and digital signals as well as HART® signals. A wide product range with both loop-powered and universal isolators featuring linearisation, inversion, and scaling of output signals.



Temperature A wide selection of transmitters for DIN form B mounting and DIN rail devices with analogue and digital bus communication ranging from application-specific to universal transmitters.



Universal PC or front programmable devices with universal options for input, output and supply. This range offers a number of advanced features such as process calibration, linearisation and auto-diagnosis.



PR



www.prelectronics.fr



sales@prelectronics.fr



www.prelectronics.de



sales@prelectronics.de



www.prelectronics.es



sales@prelectronics.es



www.prelectronics.it



sales@prelectronics.it



www.prelectronics.se



sales@prelectronics.se



www.prelectronics.co.uk



sales@prelectronics.co.uk



www.prelectronics.com



sales@prelectronics.com



www.prelectronics.cn



sales@prelectronics.cn

Head office

Denmark
PR electronics A/S
Lerbakken 10
DK-8410 Rønde

www.prelectronics.com
sales@prelectronics.dk
tel. +45 86 37 26 77
fax +45 86 37 30 85



QUALITY SYSTEM AND ENVIRONMENTAL MANAGEMENT SYSTEM
DS/EN ISO 9001
DS/EN ISO 14001

