



# 4116

Universal transmitter

No. 4116V103-UK From ser. no. 090390001











SIGNALS THE BEST

- DK ▶ PR electronics A/S tilbyder et bredt program af analoge og digitale signalbehandlingsmoduler til industriel automation. Programmet består af Isolatorer, Displays, Ex-barrierer, Temperaturtransmittere, Universaltransmittere mfl. Vi har modulerne, du kan stole på i selv barske miljøer med elektrisk støj, vibrationer og temperaturudsving, og alle produkter opfylder de strengeste internationale standarder. Vores motto »Signals the Best« er indbegrebet af denne filosofi og din garanti for kvalitet.
- UK PR electronics A/S offers a wide range of analogue and digital signal conditioning modules for industrial automation. The product range includes Isolators, Displays, Ex Interfaces, Temperature Transmitters, and Universal Modules. You can trust our products in the most extreme environments with electrical noise, vibrations and temperature fluctuations, and all products comply with the most exacting international standards. »Signals the Best« is the epitome of our philosophy and your guarantee for quality.
- FR ▶ PR electronics A/S offre une large gamme de produits pour le traitement des signaux analogiques et numériques dans tous les domaines industriels. La gamme de produits s'étend des transmetteurs de température aux afficheurs, des isolateurs aux interfaces SI, jusqu'aux modules universels. Vous pouvez compter sur nos produits même dans les conditions d'utilisation sévères, p.ex. bruit électrique, vibrations et fluctuations de température. Tous nos produits sont conformes aux normes internationales les plus strictes. Notre devise »SIGNALS the BEST« c'est notre ligne de conduite et pour vous l'assurance de la meilleure qualité.
- DE ▶ PR electronics A/S verfügt über ein breites Produktprogramm an analogen und digitalen Signalverarbeitungsmodule für die industrielle Automatisierung. Dieses Programm umfasst Displays, Temperaturtransmitter, Ex- und galvanische Signaltrenner, und Universalgeräte. Sie können unsere Geräte auch unter extremen Einsatzbedingungen wie elektrisches Rauschen, Erschütterungen und Temperaturschwingungen vertrauen, und alle Produkte von PR electronics werden in Übereinstimmung mit den strengsten internationalen Normen produziert. »Signals the Best« ist Ihre Garantie für Qualität!

# **UNIVERSAL TRANSMITTER**

# PReasy 4116

# **CONTENTS**

vvarning	2
Symbol identification	3
Safety instructions	3
EC declaration of conformity	5
How to dismantle system 4000	6
When front LED lights red / display shows AO.ER	6
Advanced features	7
Application	7
Technical characteristics	7
PR 4501 Display / programming front	8
Applications	9
Order codes	10
Electrical specifications	10
Visualisation in the 4501 of sensor error detection and	
input signal outside range	14
Sensor error detection limits	14
Error indications	15
Connections	16
Block diagram	17
Configuration / operating the function keys	18
Routing diagram	25
Routing diagram, Advanced settings (ADV.SET)	28
Routing diagram, Manual deactivation	20
of the latch function	29
Scrolling help text in display line 3	30
Graphic depiction of latch function setpoint	32
Graphic depiction of latch function window	33
Graphic depiction of relay action setpoint	34
Graphic depiction of relay action setponit	34
arapino depiction of relay action window	J4

# GENERAL

#### WARNING

This device is designed for connection to hazardous electric voltages.

Ignoring this warning can result in severe personal injury or mechanical damage.

To avoid the risk of electric shock and fire, the safety instructions of this manual must be observed and the guidelines followed. The specifications must not be exceeded, and the device must only be applied as described in the following. Prior to the commissioning of the device, this manual must be examined carefully.

Only qualified personnel (technicians) should install this device. If the equipment is used in a manner not specified by the manufacturer, the protection provided by the equipment may be impaired.



OUS

VOI TAGE

# **WARNING**

Until the device is fixed, do not connect hazardous voltages to the device.

The following operations should only be carried out on a disconnected device and under ESD safe conditions:

General mounting, connection and disconnection of wires. Troubleshooting the device.



Repair of the device and replacement of circuit breakers must be done by PR electronics A/S only.



### WARNING

To keep the safety distances, the relay contacts on the device must not be connected to both hazardous and non-hazardous voltages at the same time.

SYSTEM 4000 must be mounted on a DIN rail according to DIN 46277.



#### WARNING

Do not open the front plate of the device as this will cause damage to the connector for the display / programming front PR 4501. This device contains no DIP-switches or jumpers.

#### SYMBOL IDENTIFICATION



**Triangle with an exclamation mark:** Warning / demand. Potentially lethal situations.



The CE mark proves the compliance of the device with the essential requirements of the directives.



The double insulation symbol shows that the device is protected by double or reinforced insulation.

# SAFETY INSTRUCTIONS

#### **DEFINITIONS**

**Hazardous voltages** have been defined as the ranges: 75 to 1500 Volt DC, and 50 to 1000 Volt AC.

**Technicians** are qualified persons educated or trained to mount, operate, and also troubleshoot technically correct and in accordance with safety regulations. **Operators**, being familiar with the contents of this manual, adjust and operate the knobs or potentiometers during normal operation.

#### RECEIPT AND UNPACKING

Unpack the device without damaging it. The packing should always follow the device until this has been permanently mounted.

Check at the receipt of the device whether the type corresponds to the one ordered.

#### ENVIRONMENT

Avoid direct sunlight, dust, high temperatures, mechanical vibrations and shock, as well as rain and heavy moisture. If necessary, heating in excess of the stated limits for ambient temperatures should be avoided by way of ventilation. All devices fall under Installation Category II, Pollution Degree 1, and Insulation Class II

#### MOUNTING

Only technicians who are familiar with the technical terms, warnings, and instructions in the manual and who are able to follow these should connect the device.

Should there be any doubt as to the correct handling of the device, please contact your local distributor or, alternatively,

PR electronics A/S www.prelectronics.com Mounting and connection of the device should comply with national legislation for mounting of electric materials, i.e. wire cross section, protective fuse, and location. Descriptions of input / output and supply connections are shown in the block diagram and side label.

The following apply to fixed hazardous voltages-connected devices:

The max. size of the protective fuse is 10 A and, together with a power switch, it should be easily accessible and close to the device. The power switch should be marked with a label indicating that it will switch off the voltage to the device.

Year of manufacture can be taken from the first two digits in the serial number.

#### **UL INSTALLATION REQUIREMENTS**

#### CALIBRATION AND ADJUSTMENT

During calibration and adjustment, the measuring and connection of external voltages must be carried out according to the specifications of this manual. The technician must use tools and instruments that are safe to use.

#### NORMAL OPERATION

Operators are only allowed to adjust and operate devices that are safely fixed in panels, etc., thus avoiding the danger of personal injury and damage. This means there is no electrical shock hazard, and the device is easily accessible.

#### **CLEANING**

When disconnected, the device may be cleaned with a cloth moistened with distilled water

#### LIABILITY

To the extent that the instructions in this manual are not strictly observed, the customer cannot advance a demand against PR electronics A/S that would otherwise exist according to the concluded sales agreement.

# **EC DECLARATION OF CONFORMITY**

As manufacturer

PR electronics A/S Lerbakken 10 DK-8410 Rønde

hereby declares that the following product:

Type: 4116

Name: Universal transmitter

is in conformity with the following directives and standards:

The EMC Directive 2004/108/EC and later amendments

EN 61326-1

For specification of the acceptable EMC performance level, refer to the electrical specifications for the module.

The Low Voltage Directive 2006/95/EC and later amendments

EN 61010-1

Rønde, 28 August 2009

Kim Rasmussen Manufacturer's signature

### **HOW TO DISMANTLE SYSTEM 4000**

First, remember to demount the connectors with hazardous voltages.



#### Picture 1:

Detach the device from the DIN rail by lifting the bottom lock.

# When front LED lights red / display shows AO.ER

PR 4116 is designed as a SIL 2 device with a high safety level. Therefore, a continuous measurement of the outgoing current is carried out on a 4...20 mA output signal. If the current is 0, an error mode switches on the red front LED and disables the relays. This function is not a default option but must be actively selected in the menu. The error mode can only be reset by switching off and then switching on the supply voltage to the device.

# UNIVERSAL TRANSMITTER PReasy 4116

- Input for RTD, TC, Ohm, potentiometer, mA and V
- 2-wire supply > 16 V
- FM-approved for installation in Div. 2
- Output for current, voltage and 2 relays
- Universal AC or DC supply

#### Advanced features

 Programmable via detachable display front (4501), process calibration, signal and relay simulation, password protection, error diagnostics and selection of help text in several languages.

### **Application**

- · Linearised, electronic temperature measurement with RTD or TC sensor.
- Conversion of linear resistance variation to a standard analogue current / voltage signal, i.e. from solenoids and butterfly valves or linear movements with attached potentiometer.
- · Power supply and signal isolator for 2-wire transmitters.
- Process control with 2 pairs of potential-free relay contacts and analogue output.
- Galvanic separation of analogue signals and measurement of floating signals.
- The 4116 is designed according to strict safety requirements and is thus suitable for application in SIL 2 installations.

#### Technical characteristics

- When 4116 is used in combination with the 4501 display / programming front, all operational parameters can be modified to suit any application. As the 4116 is designed with electronic hardware switches, it is not necessary to open the device for setting of DIP switches.
- A green / red front LED indicates normal operation and malfunction. A yellow LED is ON for each active output relay.
- · Continuous check of vital stored data for safety reasons.
- 4-port 2.3 kVAC galvanic isolation.

#### PR 4501 DISPLAY / PROGRAMMING FRONT



#### **Functionality**

The simple and easily understandable PReasy menu structure and the explanatory help texts guide you effortlessly and automatically through the configuration steps, thus making the product very easy to use. Functions and configuration options are described in the section "Configuration / operating the function keys".

#### **Application**

- · Communications interface for modification of operational parameters in 4116.
- Can be moved from one 4116 device to another and download the configuration of the first transmitter to subsequent transmitters.
- · Fixed display for readout of process data and status.

#### Technical characteristics


- LCD display with 4 lines; Line 1 (H=5.57 mm) shows input signal, line 2 (H=3.33 mm) shows units, line 3 (H=3.33 mm) shows analogue output or tag no. and line 4 shows communication and relay status.
- Programming access can be blocked by assigning a password. The
  password is saved in the transmitter in order to ensure a high degree of
  protection against unauthorised modifications to the configuration.

#### Mounting / installation

Click 4501 onto the front of 4116.


# **APPLICATIONS**

# Input signals:




Output signals:

Order separately: 5910 CJC connector. See the connection drawing on page 39.



# Supply:



#### Order codes

4116 = Universal transmitter

4501 = Display / programming front

5910 = CJC connector

# **Electrical specifications**

Specifications range..... -20°C to +60°C

Common specifications:

mA / V input..... ≤ 400 ms

Accuracy, the greater of the general and basic values:

General values			
Input Absolute		Temperature coefficient	
type accuracy		coefficient	
All	$\leq \pm 0.1\%$ of span	$\leq$ ±0.01% of span / °C	

10 4116V103

Basic values			
Input type	Basic accuracy	Temperature coefficient	
mA	≤ ±4 µA	≤ ±0.4 µA / °C	
Volt	≤ ±20 µV	≤ ±2 μV / °C	
Pt100	≤ ±0.2°C	≤ ±0.01°C / °C	
Linear resistance	≤ ±0.1 Ω	≤ ±0.01 Ω / °C	
Potentiometer	≤ ±0.1 Ω	≤ ±0.01 Ω / °C	
TC type: E, J, K, L, N, T, U	≤ ±1°C	≤ ±0.05°C / °C	
TC type: R, S, W3, W5, LR	≤ ±2°C	≤ ±0.2°C / °C	
TC type: B 160400°C	≤ ±4.5°C	≤ ±0.45°C / °C	
TC type: B 4001820°C	≤ ±2°C	≤ ±0.2°C / °C	

EMC immunity influence < ±0.5% of span	
Extended EMC immunity:	
NAMUR NE 21, A criterion, burst < ±1% of span	

#### Auxiliary supplies:

2-wire supply (terminal 4443)	2516 VDC / 020 mA
Max. wire size	1 x 2.5 mm <sup>2</sup> stranded wire
Screw terminal torque	0.5 Nm
Relative humidity	< 95% RH (non-cond.)
Dimensions, without display front (HxBxD)	109 x 23.5 x 104 mm
Dimensions, with display front (HxBxD)	109 x 23.5 x 116 mm
Protection degree	IP20
Weight	170 a / 185 a with 4501

# RTD, linear resistance and potentiometer input:

Input	Min.	Max.	Standard
type	value	value	
Pt100	-200°C	+850°C	IEC60751
Ni100	-60°C	+250°C	DIN 43760
Lin. R	0 Ω	10000 Ω	-
Potentiometer	10 Ω	100 kΩ	-

Input for RTD types:

Pt10, Pt20, Pt50, Pt100, Pt200, PT250, Pt300, Pt400, Pt500, Pt1000 Ni50, Ni100, Ni120, Ni1000

Cable resistance per wire (max.), RTD	50 Ω
Sensor current, RTD	Nom. 0.2 mA
Effect of sensor cable resistance	
(3- / 4-wire), RTD	$<$ 0.002 $\Omega$ / $\Omega$
Sensor error detection, RTD	Yes
Short circuit detection, RTD	< 15 Ω

#### TC input:

Туре	Min. value	Max. value	Standard
В	0°C	+1820°C	IEC 60584-1
E	-100°C	+1000°C	IEC 60584-1
J	-100°C	+1200°C	IEC 60584-1
K	-180°C	+1372°C	IEC 60584-1
L	-200°C	+900°C	DIN 43710
N	-180°C	+1300°C	IEC 60584-1
R	-50°C	+1760°C	IEC 60584-1
S	-50°C	+1760°C	IEC 60584-1
T	-200°C	+400°C	IEC 60584-1
U	-200°C	+600°C	DIN 43710
W3	0°C	+2300°C	ASTM E988-90
W5	0°C	+2300°C	ASTM E988-90
LR	-200°C	+800°C	GOST 3044-84

Cold junction compensation (CJC): via external sensor in connector 5910 .... 20...28°C ≤ ±1°C -20...20°C / 28...70°C <+2°C via internal CJC sensor ......  $\pm (2.0^{\circ}\text{C} + 0.4^{\circ}\text{C} * \Delta t)$  $\Delta t$  = internal temperature - ambient temperature Sensor error detection, all TC types ...... Yes Sensor error current: when detecting...... Nom. 2 µA else...... 0 uA Current input: Measurement range ...... 0...20 mA Programmable measurement ranges....... 0...20 and 4...20 mA Sensor error detection: Loop break 4...20 mA..... Yes Voltage input: Measurement range ...... 0...12 VDC Programmable measurement ranges....... 0...1 / 0.2...1 / 0...5 / 1...5 / 0...10 and 2...10 VDC 

0	
Current output: Signal range (span)	0 20 mA
Programmable signal ranges	
Load (max.)	
Load stability	
Sensor error detection	
NAMUR NE 43 Upscale / Downscale	23 mA / 3.5 mA
Output limitation:	
on 420 and 204 mA signals	
on 020 and 200 mA signals	
Current limit	≤ 28 mA
Voltage output:	
Signal range	
Programmable signal ranges	
	15 / 210 / 10 / 10.2 / 50 /
1 1/ : )	51 / 100 og 102 V
Load (min.)	500 KΩ
Relay outputs:	
Relay functions	
	Power and Off
Hysteresis, in % / display counts	
On and Off delay Sensor error detection	
Max. voltage	
Max. current	
Max. AC power	
Ex / I.S. approval:	
FM, applicable in	Class I Div 2 Group A B C D
TW, applicable illinininininininininininininininininin	Class I, Div. 2, Group IIC
	Zone 2
Max. ambient temperature for T5	60°C
Marine approval:	
Det Norske Veritas, Ships & Offshore	Standard for Certification No. 2.4
GOST R approval:	
VNIIM, Cert. no	See www.prelectronics.com
Observed authority requirements:	•
EMC 2004/108/EC	
LVD 2006/95/EC	
FM	
UL, Standard for Safety	
- ,	

of span = of the currently selected measurement range

# Visualisation in the 4501 of sensor error detection and input signal outside range

Sensor error check:			
Device: Configuration Sensor error detection:			
4116	R1, ERR.ACT=NONE - R2, ERR.ACT=NONE, OUT.ERR=NONE.	OFF	
	Else:	ON	

Outside range readout (IN.LO, IN.HI):  If the valid range of the A/D converter or the polynomial is exceeded			
Input	Range	Readout	Limit
	01 V / 0.21 V	IN.LO	< -25 mV
VOLT	01 V / 0.21 V	IN.HI	> 1.2 V
VOLI	010 V / 210 V	IN.LO	< -25 mV
	010 V / 210 V	IN.HI	> 12 V
CURR	020 mA / 420 mA	IN.LO	< -1.05 mA
CURR		IN.HI	> 25.05 mA
	0800 Ω	IN.LO	< 0 Ω
	0800 \$2	IN.HI	> 1075 Ω
LIN.R	010 kΩ	IN.LO	< 0 Ω
		IN.HI	< 110 kΩ
РОТМ	-	IN.LO	< -0.5 %
POTW		IN.HI	> 100.5 %
TEMP	TC / RTD	IN.LO	< temperature range -2°C
IEMP		IN.HI	> temperature range +2°C

Display readout below min / above max. (-1999, 9999):			
Input	Range	Readout	Limit
All	All All	-1999	Display readout <-1999
All	All All		Display readout >9999

#### Sensor error detection limits

Sensor error detection (SE.BR, SE.SH):				
Input	Range	Readout	Limit	
CURR	Loop break (420 mA)	SE.BR	<= 3.6 mA; > = 21 mA	
POTM	All, SE.BR on all 3-wire	SE.BR	> ca. 126 kΩ	
LIN.R	0800 Ω	SE.BR	> ca. 875 Ω	
	010 kΩ	SE.BR	> ca. 11 kΩ	
TEMP	TC	SE.BR	> ca. 750 kΩ / (1.25 V)	
	RTD, 2-, 3-, and 4-wire	SE.BR	> ca. 15 kΩ	
	No SE.SH for Pt10, Pt20 and Pt50	SE.SH	< ca. 15 Ω	

#### Error indications

Readout at hardware error				
Error search	Readout	Error cause		
Test of internal CJC sensor	CJ.ER	CJC sensor defect or tem-		
lest of internal CJC sensor		perature outside range		
Checksum test of the configuration in FLASH	FL.ER	Error in FLASH		
Check measurement of analogue output current	AO.ER	1) No load on the current out-		
Check measurement of analogue output current		put (only S420/S204 mA)		
Communications test 4501 / 4116	NO.CO	Connection error		
Check that input signal matches input configuration	IN.ER	1) Error levels on input		
Check that saved configuration in 4501 matches device	TY.ER	Configuration is not 4116		

! Error indications in the display flash once per second. The help text explains the error.


<sup>1)</sup> The error is reset by switching off and then switching on the supply voltage to the device.

# **CONNECTIONS**


# Supply:



# Inputs:




# Outputs:



16 4116V103

# **BLOCK DIAGRAM**



# CONFIGURATION / OPERATING THE FUNCTION KEYS

Documentation for routing diagram.

#### In general

When configuring the 4116, you will be guided through all parameters and you can choose the settings which fit the application. For each menu there is a scrolling help text which is automatically shown in line 3 on the display.

Configuration is carried out by use of the 3 function keys:

- will increase the numerical value or choose the next parameter
- will decrease the numerical value or choose the previous parameter
- will accept the chosen value and proceed to the next menu

When configuration is completed, the display will return to the default state 1.0.

Pressing and holding ® will return to the previous menu or return to the default state (1.0) without saving the changed values or parameters.

If no key is activated for 1 minute, the display will return to the default state (1.0) without saving the changed values or parameters.

#### Further explanations

Fast setpoint adjustment and relay test: These menus allow you to make a quick setpoint change and relay test when the FastSet menu is activated. This function can only be activated when the relays are set for setpoint function and are controlled by a setpoint.

Pressing  $\otimes$  and  $\otimes$  simultaneously will activate a relay test and change the state of the relay.

Pressing will save the setpoint change.

Holding down 

for more than 1 second will return the unit to the default state without saving the setpoint change.

Password protection: Programming access can be blocked by assigning a password. The password is saved in the transmitter in order to ensure a high degree of protection against unauthorised modifications to the configuration. Default password 2008 allows access to all configuration menus.

#### Signal and sensor error info via display front 4501

Sensor error (see limits in the table) is displayed as SE.BR (sensor break) or SE.SH (sensor short). Signals outside the selected range (not sensor error, see table for limits) are displayed as IN.LO indicating low input signal or IN.HI indicating high input signal. The error indication is displayed in line 3 as text and at the same time the backlight flashes. Line 4 of the display is a status line which displays status of relay 1 and relay 2, COM (flashing bullet) indicating correct functioning of 4501 and arrow up/down which indicates tendency readout of the input signal. If the figure 1 or figure 2 flashes, the unit has detected that the setpoint has been exceeded and that the relay is in "delay" mode. When the delay time has passed and the relay makes/breakes, the relay sign either displays or disappears.

#### Signal and sensor error indication without display front

Status of the unit can also be read from the red/green LED in the front of the device.

Green flashing LED 13 Hz indicates normal operation.

Green flashing LED 1 Hz indicates sensor error.

Steady red LED indicates internal error.

#### Relay functions

6 different settings of relay function can be selected.

**Setpoint:** The unit works as a single limit switch

Window: The relay has a window that is defined by a low and a high

setpoint. On both sides of the window the relay has the

same status.

Error function: The relay is activated by sensor error.

**Power:** The relay is activated as long as the power is on.

Off: The relay is deactivated.

**Latch:** The relay is latched. Only valid for setpoint and window

function.

Increasing/decreasing: The relays can be set to activate at increasing or decreasing input signal.

**Delay:** An ON and an OFF delay can be set on both relays in the range 0, 3600 s.

**Hysteresis:** A hysteresis can be set at 0.1...25% of the span or between 1 and 2999 counts.

#### Latch

- When the setpoint is exceeded the relay outputs enters an alarm state. The latch function of the 4116 will hold the relays in this state until the function is deactivated manually. The latch function can be applied when the relay function setpoint or window is selected.
- The latch function can be selected separately for each relay output. If the configuration is copied from one device to another by way of the 4501, the latch function must be reconfigured.
- The latch function activates and holds the relays when the input signal rises above or falls below the selected setpoints and the relay action has been selected as increasing or decreasing.
- The window function is selected by choosing "window" in the menu and defining a high and a low setpoint.
- It can be selected for each relay contact whether the contact is open or closed inside the window. This selection is made in the menu R1.cont and R2.cont.
- The setpoint function is selected by choosing "setpoint" in the menu and entering the desired limit. The device then works as a single limit switch.
- An activated relay means that the contact is closed if the contact function "normally open" is selected, and the contact is open if the contact function "normally closed" is selected.
- The delay time for activation and deactivation can be set independently of each other in the menus ON.DEL and OFF DEL respectively.
- If the relay function "Error" is active, the relay will latch when a sensor error occurs and will not be deactivated automatically when the sensor error is rectified.
- The relay can only be deactivated by an operator and only when the normal conditions for deactivation are met. If the input signal still has a value that will activate the relay, the relay will latch again.
- See the graphic depiction of the setpoint and window functions on pages 32 and 33

#### Manual deactivation of the latch function

If the relay outputs are activated and thereby latched, it will be indicated in the display. The backlight flashes and the scrolling help text tells you how to deactivate the output. Manual deactivation is carried out by way of the front buttons on the 4501. Use ⊘ and ⊘ to navigate in the menu and ⊛ to validate your selection. If the password protection has been activated, the password must be entered in order to access the deactivation menu. See the menu structure on page 29.

#### Advanced functions

The device gives access to a number of advanced functions which can be reached by answering "Yes" to the point "adv.set".

**Display setup:** Here you can adjust the brightness contrast and the backlight. Setup of TAG numbers with 6 alphanumerics. Selection of functional readout in line 3 of the display - choose between readout of analogue output or tag no.

**Two-point process calibration:** The device can be process-calibrated in 2 points to fit a given input signal . A low input signal (not necessarily 0%) is applied and the actual value is entered via 4501. Then a high signal (not necessarily 100%) is applied and the actual value is entered via 4501. If you accept to use the calibration, the device will work according to this new adjustment. If you later reject this menu point or choose another type of input signal the device will return to factory calibration.

Process simulation function: If you agree to the point "EN.SIM" it is possible to simulate an input signal by means of the arrow keys and thus control the output signal up or down. When you finalise the point with ⊛, the device returns to normal mode. The following point allows you to activate relay 1 and relay 2 by means of the arrow-keys up/down. You must exit the menu by pressing ⊛ (no time-out).

Password: Here you can choose a password between 0000 and 9999 in order to protect the device against unauthorised modifications to the configuration. The device is delivered default without password. If you have locked the device with a password by mistake, you can always open the menu by using the master password 2008.

Language: In the menu "lang.setup" you can choose between 7 different language versions of help texts that will appear in the menu. You can choose between UK, DE, FR, IT, ES, SE and DK.

# **Auto diagnosis**

The device performs an advanced auto diagnosis of the internal circuits.

The following possible errors can by displayed in the front unit 4501.

CJ.ER - CJC sensor defect or CJC temperature outside range

FL.ER - Flash error

AO.ER - No load on the current output (only for S4...20 mA / S20...4 mA)

NO.CO - Connection error

IN.ER - Error levels on input

TY.ER - Configuration in 4501 does not match this product type

#### Selection of units

After choosing the input signal type you can choose which process units should be displayed in text line 2 (see table). By selection of temperature input the process value is always displayed in Celsius or Fahrenheit. This is selected in the menu point after selection of temperature input.

#### Safety readback


When the device is delivered with default configuration, the SIL function is disabled. The safety readback function (loop surveillance) can be selected in the menu O.RANGE, thus enabling the device to run in SIL mode. In order to enable the SIL functionality, the menu item S4...20 mA must be selected. Please note, however, that when safety readback is enabled, a sensor error will be indicated as an error on the analogue output signal.

#### CJC

In the CJC menu you can choose between CJC connector and internal cold junction compensation. The CJC connecter (PR 5910) must be ordered separately.

#### Memory

In the memory menu you can save the configuration of the device in the 4501, and then move the 4501 onto another device of the same type and download the configuration in the new device.




#### **ROUTING DIAGRAM**


If no key is activated for 1 minute, the display will return to the default state 1.0 without saving configuration changes.


- ® Accept the chosen value and proceed to the next menu

Hold 

Back to previous menu / return to menu 1.0 without saving









#### **ROUTING DIAGRAM**

Advanced settings (ADV.SET)



# **ROUTING DIAGRAM**

# Manual deactivation of the latch function



#### SCROLLING HELP TEXT IN DISPLAY LINE 3

- [01] Set correct password
- [02] Enter advanced setup menu?
- [03] Select temperature input Select potentiometer input Select linear resistance input

Select current input Select voltage input

[04] Select 0.0-1 V input range Select 0.2-1 V input range Select 0-5 V input range

Select 1-5 V input range Select 0-10 V input range

Select 2-10 V input range [05] Select 0-20 mA input range Select 4-20 mA input range

[06] Select 2-wire sensor connection Select 3-wire sensor connection Select 4-wire sensor connection

[07] Set resistance value low

[08] Set resistance value high

[09] Select Celsius as temperature unit Select Fahrenheit as temperature unit

[10] Select TC sensor type Select Ni sensor type Select Pt sensor type

[11] Select display unit

121 Select decimal point position

[13] Set display range low

[14] Set display range high

[15] Set relays in % of input range Set relays in display units [16] Select Pt10 as sensor type

Select Pt20 as sensor type Select Pt50 as sensor type Select Pt100 as sensor type Select Pt200 as sensor type Select Pt250 as sensor type Select Pt300 as sensor type Select Pt400 as sensor type Select Pt500 as sensor type Select Pt1000 as sensor type

[17] Select Ni50 as sensor type Select Ni100 as sensor type Select Ni120 as sensor type Select Ni1000 as sensor type

[18] Select TC-B as sensor type Select TC-E as sensor type Select TC-J as sensor type Select TC-K as sensor type Select TC-L as sensor type Select TC-N as sensor type

Select TC-R as sensor type Select TC-S as sensor type Select TC-T as sensor type Select TC-U as sensor type

Select TC-W3 as sensor type Select TC-W5 as sensor type Select TC-Lr as sensor type

[19] Select OFF function - relay is permanently off Select POWER function - relay indicates power status OK Select ERROR function - relay indicates sensor error only

Select WINDOW function - relay controlled by 2 setpoints Select SETPOINT function - relay controlled by 1 setpoint

[20] Select Normally Closed contact Select Normally Open contact

[21] Set relay setpoint

[22] Activate relay on decreasing signal Activate relay on increasing signal

[23] Set relay hysteresis [24] No error action - undefined status at error Open relay contact at error Close relay contact at error Hold relay status at error

[25] Set relay ON delay in seconds

[26] Set relay OFF delay in seconds [27] Relay contact is Closed Inside Window

Relay contact is Open Inside Window

[28] Set relay window setpoint high [29] Set relay window setpoint low

[30] Set relay window hysteresis [31] No error action - undefined status at error Open relay contact at error

Close relay contact at error Hold relay status at error [32] Set relay ON delay in seconds

[33] Set relay OFF delay in seconds

[34] Open relay contact at error Close relay contact at error

[36] Select current as analogue output type Select voltage as analogue output type

[37] Select 0-20 mA output range Select 4-20 mA output range Select S4-20 mA with safety readback Select 20-0 mA output range Select 20-4 mA output range

Select S20-4 mA with safety readback [38] Select no error action - output undefined at error

Select downscale at error Select NAMUR NE43 downscale at error Select NAMLIR NE43 upscale at error

[39] Select 0.0-1 V output range Select 0.2-1 V output range

> Select 0-5 V output range Select 1-5 V output range Select 0-10 V output range

Select 2-10 V output range Select 1-0.0 V output range

Select 1-0.2 V output range Select 5-0 V output range Select 5-1 V output range

Select 10-0 V output range Select 10-2 V output range [41] Set temperature for analogue output low

[42] Set temperature for analogue output high [43] Enter password setup

Enter simulation mode Perform process calibration Enter display setup Perform memory operations

Enter relay latch setup

[44] Load saved configuration into 4116 Save 4116 configuration in 4501

[45] Adjust LCD contrast [46] Adjust LCD backlight


[47] Write a 6-character device TAG

- [48] Analogue output value is shown in display line 3 Device TAG is shown in display line 3
- [49] Calibrate input low to process value?
- [50] Calibrate input high to process value?
- [51] Enable simulation mode?
- [52] Set the input simulation value
- [53] Relay simulation use 


  and 

  to toggle relay 1 and 2
- [54] Enable password protection?
- [55] Set new password
- [56] Enable Fastset functionality?
- [57] Relay setpoint press @ to save
- [58] Relay setpoint Read only
- [59] Select language
- [60] Use process calibration values?
- [61] Set value for low calibration point
- [62] Set value for high calibration point
- [63] Select CJC connector (accessory) Select internal temperature sensor
- [64] Enable relay latch function?
- [65] Relay is latched press @ to acknowledge
  - Relay 1 is latched press ⊗ to release
    - Relay 2 is latched press ⊗ to release
  - Relays are latched press ⊗ or ⊗ tor release relay 1 or relay 2
- [66] Release relay? (if conditions allow)
- [67] Enter setup menu? (latched relays may release!)


# Graphic depiction of latch function setpoint




# Graphic depiction of latch function window



# Graphic depiction of relay action setpoint



#### Graphic depiction of relay action window



Relay function: Window (shown for increasing signal)
Contact: Closed inside window = 
Contact: Open inside window = 
Contact

Relay function: Window (shown for decreasing signal)

Contact: Closed inside window = 

Contact: Open inside window =



**Displays** Programmable displays with a wide selection of inputs and outputs for display of temperature, volume and weight, etc. Feature linearisation, scaling, and difference measurement functions for programming via PReset software



Ex interfaces Interfaces for analogue and digital signals as well as HART® signals between sensors / I/P converters / frequency signals and control systems in Ex zone 0, 1 & 2 and for some modules in zone 20, 21 & 22.



**Isolation** Galvanic isolators for analogue and digital signals as well as HART® signals. A wide product range with both loop-powered and universal isolators featuring linearisation, inversion, and scaling of output signals.





of Temperature A wide selection transmitters for DIN form В mounting DIN modules with analogue rail and digital hus communication ranging from applicationspecific to universal transmitters.



Universal PC or front programmable modules with universal options for input, output and supply. This range offers a number of advanced features such as process calibration, linearisation and autodiagnosis.







www.prelectronics.es
sales@prelectronics.es

www.prelectronics.it
sales@prelectronics.it

www.prelectronics.se sales@prelectronics.se

www.prelectronics.co.uk
si sales@prelectronics.co.uk

www.prelectronics.comsales@prelectronics.com

# **Head office**

Denmark PR electronics A/S Lerbakken 10 DK-8410 Rønde www.prelectronics.com sales@prelectronics.dk tel. +45 86 37 26 77 fax +45 86 37 30 85







