



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx KEM 10.0084X issue No.:1

Status: **Current**

Certificate history:
Issue No. 1 (2011-12-21)
Issue No. 0 (2010-10-4)

Date of Issue: **2011-12-21** Page 1 of 4

Applicant: **PR electronics A/S**
Lerbakken 10
8410 Rønne
Denmark

Electrical Apparatus: **2-Wire Transmitter with HART Protocol, Types 6335A, 6335D, 6336A, 6336D, 6337A and 6337D**
Optional accessory:

Type of Protection: **Ex ia for Types 633*D; Ex nA [ic] and Ex ic for Types 633*A**

Marking: **Ex ia IIC T5 Ga
Ex ia IIIC Da
Ex nA [ic] IIC T6 ... T4 Gc or
Ex ic IIC T6 ... T4 Gc or
Ex ic IIIC Dc**


Approved for issue on behalf of the IECEx
Certification Body:

C.G. van Es

Position:

Certification Manager

Signature:
(for printed version)



Date:

2011-12-21

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

DEKRA Certification B.V.
Utrechtseweg 310
6812 AR Arnhem
The Netherlands

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.





IECEX Certificate of Conformity

Certificate No.: IECEx KEM 10.0084X

Date of Issue: 2011-12-21

Issue No.: 1

Page 2 of 4

Manufacturer: **PR electronics A/S**
Lerbakken 10
8410 Rønne
Denmark

Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2007-10 Edition: 5	Explosive atmospheres - Part 0: Equipment - General requirements
IEC 60079-11 : 2006 Edition: 5	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
IEC 60079-15 : 2010 Edition: 4	Explosive atmospheres - Part 15: Equipment protection by type of protection "n"
IEC 60079-26 : 2006 Edition: 2	Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga
IEC 61241-11 : 2005 Edition: 1	Electrical apparatus for use in the presence of combustible dusts - Part 11: Protection by intrinsic safety 'iD'

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

NL/KEM/ExTR10.0075/00

NL/KEM/ExTR10.0075/01

Quality Assessment Report:

NL/KEM/QAR07.0004/03



IECEx Certificate of Conformity

Certificate No.: IECEx KEM 10.0084X

Date of Issue: 2011-12-21

Issue No.: 1

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The 2-Wire Transmitters Type 6335A and Type 6335D with HART 5 protocol, Type 6336A and Type 6336D with HART 6 protocol, Type 6337A and Type 6337D with HART 7 protocol, for rail mounting, with one or two independent channels, are used to convert the measurement signal of a temperature sensor or a mV signal into a 4 ... 20 mA current signal with digital communication.

For further information, refer to the Attachment.

CONDITIONS OF CERTIFICATION: YES as shown below:

Transmitters Type 633*A in Type of protection Ex nA

The Transmitter shall be mounted in an enclosure that provides a degree of protection of at least IP54 according to IEC 60529.

For an ambient temperature ≥ 60 °C, heat resistant cables shall be used with a rating of at least 20 K above the ambient temperature.



IECEX Certificate of Conformity

Certificate No.: IECEx KEM 10.0084X

Date of Issue: 2011-12-21

Issue No.: 1

Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

- Addition of Transmitters Type 6335A and Type 6336A in type of protection Ex nA [ic] and Ex ic.
- Addition of Type 6337A and Type 6337D with similar hardware but firmware that enables them to communicate using the HART 7 protocol.
- Standards update as listed above.

Attachment 1 to IECEx KEM 10.0084, Issue 01

General product information:

The 2-Wire Transmitter Type 6335A and Type 6335D with HART 5 protocol, Type 6336A and Type 6336D with HART 6 protocol, Type 6337A and Type 6337D with HART 7 protocol, for rail mounting, with one or two independent channels are used to convert the measurement signal of a temperature sensor or a mV signal into a 4 ... 20 mA current signal with digital communication.

Type 633*A2A and Type 633*D2A are one channel versions and Type 633*A2B and Type 633*D2B have two independent channels.

Type 633*D in Type of protection Ex ia IIC

The transmitter shall be mounted in an enclosure that provides a degree of protection of at least IP20 according to IEC 60529.

Ambient temperature range -40 °C to +60 °C

Type 633*A in Type of protection Ex nA

Ambient temperature range: -40 °C to +60 °C for temperature class T6
-40 °C to +85 °C for temperature class T4

Type 633*D in Type of protection Ex ia IIIC and Type 633*A in Type of protection Ex ic IIIC

The transmitter shall be mounted in an enclosure that provides a degree of protection of at least IP6X according to IEC 60529. The surface temperature of the enclosure is equal to the ambient temperature +20 K for a dust layer with a maximum thickness of 5 mm.

Electrical data

Type of protection Ex ia:

Supply and output circuit (terminals 11 ... 14, respectively 21 ... 24):

In type of protection intrinsic safety Ex ia IIC or Ex ia IIIC, only for connection to a certified intrinsically safe circuit, with the following maximum values:

$U_i = 30 \text{ V}$; $I_i = 120 \text{ mA}$; $P_i = 0.84 \text{ W}$; $C_i = 1 \text{ nF}$; $L_i = 10 \text{ }\mu\text{H}$;

Sensor circuit (terminals 41 ... 44, respectively 51 ... 54):

In type of protection intrinsic safety Ex ia IIC or Ex ia IIIC, with following maximum values:

$U_o = 9.6 \text{ V}$; $I_o = 28 \text{ mA}$; $P_o = 67 \text{ mW}$; $C_o = 3.5 \text{ }\mu\text{F}$; $L_o = 35 \text{ mH}$;

Types of protection Ex ic and Ex nA

Supply and output circuit (terminals 11 ... 14, respectively 21 ... 24):

in type of protection non sparking Ex nA, with

$U \leq 35 \text{ Vdc}$; $I = 4 \text{ ... } 20 \text{ mA}$; or

Supply and output circuit (terminals 11 ... 14, respectively 21 ... 24):

in type of protection intrinsic safety Ex ic IIC or Ex ic IIIC, with the following maximum values (per circuit):

$U_i = 35 \text{ V}$; $C_i = 1 \text{ nF}$; $L_i = 10 \text{ }\mu\text{H}$.

Sensor circuit, thermocouple, RTD, resistance or mV (terminals 41 ... 44, respectively 51 ... 54), in type of protection intrinsic safety Ex ic IIC or Ex ic IIIC, with the following maximum values (per circuit):

$U_o = 9.6 \text{ V}$; $I_o = 28 \text{ mA}$; $P_o = 67 \text{ mW}$; $C_o = 28 \text{ }\mu\text{F}$; $L_o = 45 \text{ mH}$.