

Certificate of Compliance

Certificate Number **20080529-E231911B**
Report Reference **E231911, 2003 September 18**
Issue Date **2008 May 29**

Page 1 of 2



**Underwriters
Laboratories Inc.®**

Issued to: **PR ELECTRONICS A/S**
LERBAKKEN 10
8410 ROENDE DENMARK

*This is to certify that
representative samples of*

AUXILIARY DEVICES


Open Type Auxiliary Devices. Cat. Nos. 5202A1, 5202A2 and 5202A4. Cat. No. 5203A, followed by 1, 2 or 3, followed by F, H or I, followed by 1 or 2.

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: **UL 508 - Industrial Control Equipment
CSA-C22.2 No. 14 - Industrial Control Equipment**

Additional Information: **See Addendum for Electrical Ratings.**

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by:
Mogens Christensen, Project Engineer
Underwriters Laboratories Inc.

Reviewed by:
Paw Rosenvard, Project Engineer
Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number **20080529-E231911B**
Report Reference **E231911, 2003 September 18**
Issue Date **2008 May 29**

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Electrical Ratings:

Cat. No.	Supply Voltage	Max Load, W	Input	Output
5202A1	24-230 VAC 24-250 VDC	1.5 W	Namur or Contact	Solid State Output - 30 V DC, 80 mA, General purpose 30 V DC, 80 mA, Pilot Duty
5202A2	24-230 VAC 24-250 VDC	1.5 W	Namur or Contact	Relay Output - General Purpose - 250 V AC, max 100 VA 2 A AC, max 100 VA 24 V DC, 1A Pilot Duty - 120/240 V AC: 100 VA
5202A4	24-230 VAC 24-250 VDC	2.0 W	Namur or Contact	Relay Output - General Purpose - 250 V AC, max 100 VA 2 A AC, max 100 VA 24 V DC, 1A Pilot Duty - 120/240 V AC: 100 VA
5203A	24-230 VAC 24-250 VDC	4.0 W	PNP, NPN or Contact	Voltage Output - Impedance limited 0-28 V DC 5203AxFx: 0.115 A, 0.93 W 5203AxHx: 0.110 A, 0.77 W per channel 5203AxIx: 0.093 A, 0.65 W

Issued by:
Mogens Christensen, Project Engineer
Underwriters Laboratories Inc.

Reviewed by:
Paw Rosenvard, Project Engineer
Underwriters Laboratories Inc.