

## EC DECLARATION OF CONFORMITY

As manufacturer

**PR electronics A/S**  
**Lerbakken 10**  
**DK-8410 Rønde**

hereby declares that the following product:

**Type: 5350**  
**Name: PROFIBUS® PA/FOUNDATION™ Fieldbus transmitter**  
**From serial no.: 150802000**

is in conformity with the following directives and standards:

The EMC Directive 2004/108/EC and later amendments  
**EN 61326-1 : 2013**

For specification of the acceptable EMC performance level, refer to the electrical specifications for the device.

The ATEX Directive 94/9/EC and later amendments

**EN 60079-0 : 2006, EN 60079-11 : 2007, EN 60079-15 : 2005,**  
**EN 60079-26 : 2007, EN 60079-27 : 2006, EN 60079-27 : 2008,**  
**EN 61241-0 : 2006 and EN 61241-11 : 2006**  
**ATEX certificate: KEMA 03ATEX1011 X (5350A)**  
**ATEX certificate: KEMA 02ATEX1318 (5350B)**


No changes are required to enable compliance with the replacement standards:

**EN 60079-0 : 2012, EN 60079-11 : 2012 and EN 60079-15 : 2010**

Notified body

**KEMA Quality B.V. (0344)**  
**Utrechtseweg 310, 6812 AR Arnhem**  
**P.O. Box 5185, 6802 ED Arnhem**  
**The Netherlands**

Rønde, 17 September 2015

  
Stig Lindemann, CTO  
Manufacturer's signature