

(1) **EC-TYPE EXAMINATION CERTIFICATE**


(2) **Equipment and protective systems intended for use in potentially explosive atmospheres - Directive 94/9/EC**

- (3) EC-Type Examination Certificate Number: **KEMA 06ATEX0115** Issue Number: **2**
- (4) Equipment: **2-wire Programmable Transmitter Type 6331B2A, 6331B2B, 6334B2A and 6334B2B**
- (5) Manufacturer: **PR electronics A/S**
- (6) Address: **Lerbakken 10, 8410 Rønne, Denmark**
- (7) This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- (8) KEMA Quality B.V., notified body number 0344 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the directive.
- The examination and test results are recorded in confidential test report number 212575000/6.
- (9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:
- EN 60079-0 : 2006 EN 60079-11 : 2007 EN 60079-26 : 2007**
- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.
- (11) This EC-Type Examination Certificate relates only to the design, examination and tests of the specified equipment according to the Directive 94/9/EC. Further requirements of the directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.
- (12) The marking of the equipment shall include the following:

**II 1 G****Ex ia IIC T6 ... T5**

This certificate is issued on October 6, 2009 and, as far as applicable, shall be revised before the date of cessation of presumption of conformity of (one of) the standards mentioned above as communicated in the Official Journal of the European Union.

KEMA Quality B.V.


C.G. van Es
Certification Manager

Page 1/2



© Integral publication of this certificate and adjoining reports is allowed. This Certificate may only be reproduced in its entirety and without any change.

KEMA Quality B.V. Utrechtseweg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem The Netherlands
T +31 26 3 56 20 00 F +31 26 3 52 58 00 customer@kema.com www.kema.com Registered Arnhem 09085396

Experience you can trust.

(13) **SCHEDULE**

(14) **to EC-Type Examination Certificate KEMA 06ATEX0115**

Issue No. 2

(15) **Description**

The 2-wire Programmable Transmitter Type 6331B2A, 6331B2B, 6334B2A and 6334B2B, for rail mounting, with one or two independent channels is used to convert the temperature measurement signal of a temperature sensor or a mV signal into a 4 ... 20 mA current signal.

Ambient temperature range for T6: -40 °C ... +40 °C.

Ambient temperature range for T5: -40 °C ... +60 °C.

Electrical data

Supply and output circuits (terminals 11 ... 13, respectively 21 ... 23):
in type of protection intrinsic safety Ex ia IIC, only for connection to a certified intrinsically safe fieldbus, with following maximum values:

$U_i = 30 \text{ V}$; $I_i = 120 \text{ mA}$; $P_i = 0,84 \text{ W}$; $C_i = 1 \text{ nF}$; $L_i = 10 \text{ }\mu\text{H}$

Sensor circuits, Thermocouple, RTD, resistance or mV (terminals 41 ... 44, respectively 51 ... 54):
in type of protection intrinsic safety Ex ia IIC, with following maximum values:

$U_o = 9,6 \text{ V}$; $I_o = 25 \text{ mA}$; $P_o = 60 \text{ mW}$; $C_o = 2,4 \text{ }\mu\text{F}$; $L_o = 33 \text{ mH}$.

Installation instructions

The sensor circuit is not infallibly galvanically isolated from the supply/output circuit.
However, the galvanic isolation between the circuits is capable of withstanding a test voltage of 500 Vac during 1 minute.

(16) **Test Report**

KEMA No. 212575000/6.

(17) **Special conditions for safe use**

None.

(18) **Essential Health and Safety Requirements**

Covered by the standards listed at (9).

(19) **Test documentation**

As listed in Test Report No. 212575000/6.