

# Certificate of Compliance

Certificate Number **20081015-E314307**  
Report Reference **E314307-A2-UL-1, 2008 October 10**  
Issue Date **2008 October 15**

Page 1 of 2



**Underwriters  
Laboratories Inc.®**

*Issued to:* **PR ELECTRONICS A/S**  
LERBAKKEN 10  
8410 ROENDE DENMARK

*This is to certify that  
representative samples of*

**PROCESS CONTROL EQUIPMENT, ELECTRICAL**  
Power Control Unit - Model 9410

*Have been investigated by Underwriters Laboratories Inc.® in  
accordance with the Standard(s) indicated on this Certificate.*


*Standard(s) for Safety:*

UL 61010-1 - Electrical Equipment for Measurement, Control, and Laboratory Use; Part 1: General Requirements - Second Edition  
CAN/CSA-C22.2 No. 61010-1 - Electrical Equipment for Measurement, Control, and Laboratory Use; Part 1: General Requirements - Second Edition

*Additional Information:*

See Addendum for Electrical Ratings

**Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.**

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

Issued by:  
**Erling Jakobsen, Senior Engineering Associate**  
Underwriters Laboratories Inc.

Reviewed by:  
**Lars Groennegaard, Staff Engineer**  
Underwriters Laboratories Inc.

# Certificate of Compliance

Certificate Number **20081015-E314307**  
Report Reference **E314307-A2-UL-1, 2008 October 10**  
Issue Date **2008 October 15**

Page 2 of 2



**Underwriters  
Laboratories Inc.®**

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## RATINGS:

Supply Input Voltage: 21.6 - 26.4 VDC  
Max 2W internal power consumption.  
Output voltage: Input Voltage -0.5V  
Output current max 4A.  
Output relay AC rated: 250Vac, 2A, 500VA  
Output relay DC rated: 30VDC, 2A, 60W

Issued by:  
**Erling Jakobsen, Senior Engineering Associate**  
Underwriters Laboratories Inc.

Reviewed by:  
**Lars Groennegaard, Staff Engineer**  
Underwriters Laboratories Inc.