



The manufacturer may use the mark:



Revision 2.2 Aug 22, 2024
Surveillance Audit Due
October 15, 2024



Certificate / Certificat Zertifikat / 合格証

PREI 16031107 P002 C008

exida hereby confirms that the:

**PR5435 / PR5437 / PR6437
Temperature Transmitters**

Product Version V01.xx.xx

**PR electronics A/S
Rønne - Denmark**

Have been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-7

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type B Element

SIL 2 @ HFT=0; SIL 3 @ HFT = 1; Route 1_H

**PFH/PFD_{avg} and Architecture Constraints
must be verified for each application**

Safety Function:

The PR5435, PR5437 and PR6437 Temperature Transmitters convert various sensor input signals from hazardous areas to a 4..20 mA current output signal with a safety accuracy of ±2%.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



Evaluating Assessor

Certifying Assessor

PREI 16031107 P002 C008

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type B Element

SIL 2 @ HFT=0; SIL 3 @ HFT = 1; Route 1_H

**PFH/PFD_{avg} and Architecture Constraints
must be verified for each application**

PR5435 /
PR5437 /
PR6437
Temperature
Transmitters

Systematic Capability :

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element.

IEC 61508 Failure Rates in FIT*

PR5435 / PR5437	λ_{safe}	λ_{DD}	λ_{DU}
Single sensor configuration	0	443	27
Dual sensor configuration	0	472	34
Redundant sensor configuration	0	486	22
PR6437	λ_{safe}	λ_{DD}	λ_{DU}
Single sensor configuration	0	452	28
Dual sensor configuration	0	472	34
Redundant sensor configuration	0	495	23

* FIT = 1 failure / 10⁹ hours

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: PR 1603-107-C R019 V2R1

Safety Manual: 5435_5437_6437 Safety Manual V4R0



80 N Main St
Sellersville, PA 18960